

## NWLCA Drinking Water 2016 Lead and Copper Rule Monitoring Results

### Residents receiving water from the NWLCA Treatment Plant

	Site ID #	Sample Site Location	Lead Result	Copper Result
1	752	Doe Run Road	7 ppb	0.9 mg/l
2	753	North Penryn Road	3 ppb	0.8 mg/l
3	754	North Penryn Road	1 ppb	0.3 mg/l
4	755	North Penryn Road	2 ppb	0.5 mg/l
5	756	Stiegel Valley Road	3 ppb	0.7 mg/l
6	757	South Penryn Road	< 1 ppb	< 0.01 mg/l
7	758	Stiegel Valley Road	2 ppb	0.6 mg/l
8	759	Grandview Drive	1 ppb	0.4 mg/l
9	760	Grandview Drive	8 ppb	0.8 mg/l
10	761	North Penryn Road	4,990 ppb	0.4 mg/l
		<b>90<sup>th</sup> percentile</b>	<b>8 ppb</b>	<b>0.8 mg/l</b>

90th percentile results from the samples collected were below the lead action level of 15 ppb and the copper action level of 1.3 mg/l.

### Residents receiving water from Lancaster City

	Site ID #	Sample Site Location	Lead Result	Copper Result
1	770	Fruitville Pike	4 ppb	0.2 mg/l
2	771	Lititz Road	2 ppb	0.1 mg/l
3	772	Fruitville Pike	1 ppb	0.2 mg/l
4	773	Fruitville Pike	1 ppb	0.3 mg/l
5	774	Fruitville Pike	3 ppb	0.2 mg/l
		<b>90<sup>th</sup> percentile</b>	<b>4 ppb</b>	<b>0.3 mg/l</b>

90th percentile results from the samples collected were below the lead action level of 15 ppb and the copper action level of 1.3 mg/l.