


Assistant
97 North Penryn Road
Manheim, PA 17545



NWLCA
Northwestern Lancaster County Authority

Phone: (717) 665-4508
Fax: (717) 665-4108

AGENDA
7:00 P.M., Wednesday, May 18, 2022

1. Call to Order
2. Public Comments
3. Approve April 19, 2022 Meeting Minutes
4. Treasurer's Report
 - A. Invoices
 - B. GO Bond Report
5. Communications
 - A. MAWSA Reports
6. Inframark Contract Operations Report
 - A. Approve Pump Repair, \$6,400.00
 - B. Approve Wastewater Decanter Float and Flex Joints Purchase, \$18,289.43
7. Engineer's Report
 - A. Review Tapping Fee Calculations
 - B. Recommends denying the requested relief from installation of clay dikes around the sanitary sewer piping at intervals of 200 feet due to the potential of groundwater following the privately owned sanitary sewer facilities stone trenching and potentially impacting the Authority's sanitary sewer facilities.
 - C. Recommends denying the requested relief from installation of traps, vents and cleanouts on the private apartment building service lines, since the Authority Rules and Regulations require the installation of traps, vents and cleanouts on all building service lines.
 - D. Recommends granting the requested relief from installation of cleanouts on sanitary sewer building laterals at intervals of 50 feet, with the condition that cleanouts to be installed at intervals of 100 feet.
8. Solicitor's Report
 - A. Jason Hess - Morgan, Hallgren, Crosswell, & Kane - Non-residential Waste Program Customers Non-compliance Remedies
9. Adjournment

Next NWLCA Meeting 7pm, June 21, 2022

If you are a person requiring accommodations to participate, please contact township staff to discuss how we may best meet your needs.